

Don Csaposs

From: Robert Sipzner [Rsipzner@bartonandloguidice.com]
Sent: Thursday, September 13, 2007 12:57 PM
To: Don Csaposs
Subject: 869.016 - Guilderland Ped Improvements: Comments on McKown Road

Don. I thought it would be clearer to respond in an email to make it easier to get the info on the comments to you. First, I do appreciate the comments received and it sounds like this individual is looking to have the best product he can. Kudos.

Gas Vent Pipe

The vent pipe noted is indeed as he stated, close to the walkway. It was noted by others as well. The action items in play as we speak are to make the pipe more visible to those on the walkway, likely by painting. More importantly, National Grid has been contacted by Callanan and is to come out and see if and how to modify. I can't speak to the timing of National Grid, however. Still, it did not go unnoticed.

Drainage by Williams Court

The plans called for the existing pipe he noted as being removed. Once the sidewalk is completed, drainage swales will be re-established allowing water on the back side to flow as needed and meet up with a drainage structures to be about 45 feet to the south, where flows will continue in the new swale (yet to be finished) to the tributary. Should we set once all work is completed.

Hope this helps.

Rob

Robert J. Sipzner, P.E.

Associate

BARTON & LOGUIDICE, P.C.

Engineers, Environmental Scientists, Planners, Landscape Architects

Phone: (518) 218 -1801

Fax: (518) 218 -1805

Email: rsipzner@bartonandloguidice.com

9/13/2007